



Plate : KOR 1a SOUTHCO Proposed alignment of 11 kV line under Infrastructure Development Plan Chalanguda - Kamra Chalanguda - Majhia		Proposed location of 33/11 kV S/s or Source Location Target Location Proposed 11 kV Line 1 Proposed 11 kV Line 2	<p>Chalanguda Kamra Estimated Length of 11 kV line = 3.66 Km</p> <p>Chalanguda Majhia Estimated Length of 11 kV line = 3.15 Km</p>
 		Prepared by: SPARC SPARC Pvt. Ltd. E/11, Infocity, Patia Bhubaneswar	