



<b>Plate :JGS 6b</b> <b>CESU</b> Proposed alignment of 33KV line under Infrastructure Development Plan <b>Tirtol - Kanakpur</b>		Existing location of 132/33 KV s/s or Tapping location on existing 33 KV line Proposed location of 33/11 KV s/s Proposed Power Line (Option 1) Proposed Power Line (Option 2)	<p> <b>Option 1:</b>            Tirtol (Existing 132/33 KV s/s) → Paikasta (1.4 Km) → Repurpatana (1.43 Km) → Kanakpur (1.47 Km)  <b>Estimated Length of 33 KV line = 4.25 Km</b> </p> <p> <b>Option 2:</b>            Tirtol (Existing 33 KV line) → Shasan (0.37 Km) → Dihasahi (1.50 Km) → Kanakpur (3.5 Km)  <b>Estimated Length of 33 KV line = 5.35 Km</b> </p> <p>           Prepared by:  <b>SPARC</b> Spatial Planning &amp; Analysis Research Centre Pvt. Ltd.            E/11, Infocity, Patia, Bhubaneswar         </p>
--	--	--	---