Plate :PUR 2a

CESU

Proposed alignment of 33KV line under Infrastructure Development Plan

Sakhigopal - Gabakunda

N

500 250 0 500 Meters

Existing location of 132/33 KV s/s or Tapping location on existing 33 KV line

Proposed location of 33/11 KV s/s

Proposed Power Line (Option 1)

Proposed Power Line (Option 2)

85°50'0"E 85°51'0"E 85°52'0"E 85°53'0"E

19°58'0"N 19°57'0"N 19°56'0"N

Sakhigopal

Biswanathpur

Raychakradharpur

Baghua

Pahachurha

Gabakunda

2.54 Km

2.50 Km

1.00 Km

1.07 Km

1.80 Km

0.60 Km

3.1 Km

7.0 Km

Bhagabati River

Sakhigopal 2.54 Km Biswanathpur 3.50 Km Baghua 4.31Km gabakunda

Estimated Length of 33 KV line = 10.35 Km

Sakhigopal 6.04 Km Pahaehurha 0.60 Km Baghua 2.87Km Gabakunda

Estimated Length of 33 KV line = 9.51 Km

Prepared by:

SPARC Igniting Innovations

Spatial Planning & Analysis Research Centre Pvt. Ltd.
E/11, Infocity, Patia, Bhubaneswar