Plate : KEO 18b

NESCO

Proposed alignment of 33KV line under Infrastructure Development Plan

Anandpur - Chenapadi

N

1 0.5 0 1 2

Kilometers

Existing location of 132/33 KV s/s or Tapping location on existing 33 KV line

Proposed location of 33/11 KV s/s

Buffer Line(3 Km from Point)

Proposed Power Line (Option 1)

Proposed Power Line (Option 2)

Surushuria — 3.84 Km — Jalasarapur — 3.71 Km — Chenapadi

1.81 Km Anandpur — 4.73 Km Singdobh

Estimated Length of 33 KV line = 14.09 Km

Fakirapur — 4.37 Km — Chenapadi

1.66 Km Anandpur — 4.82 Km Dadhibamanpur

Estimated Length of 33 KV line = 10.85 Km

Prepared by:

SPARC

Igniting Innovations

Spatial Planning & Analysis Research Centre Pvt. Ltd.

E/11, Infocity, Patia, Bhubaneswar

86°5'0"E 86°6'0"E 86°7'0"E 86°8'0"E 86°9'0"E 86°10'0"E 86°11'0"E 86°12'0"E 86°13'0"E 86°14'0"E

21°14'0"N 21°13'0"N 21°12'0"N 21°11'0"N 21°10'0"N 21°9'0"N 21°8'0"N