Plate : NAB 3a

SOUTHCO

Proposed alignment of 11 kV line under Infrastructure Development Plan

Adhikariguda - Jamuranda
Adhikariguda - Batibeda

N

500 250 0 500

Meters

Proposed location of 33/11 KV s/s or Source Location

Target Location

Buffer Line(3 Km from Point)

Proposed Power Line 1

Proposed Power Line 2

Kutiyarigurha

1.41 Km

Kutiyarigurha

1.41 Km

2.35 Km

2.35 Km

Adhikariguda

Jamuranda

0.7 Km

Khanda

Khanda

1.96 Km

Batibeda

82°8'20"E 82°8'40"E 82°9'0"E 82°9'20"E 82°9'40"E 82°10'0"E 82°10'20"E 82°10'40"E 82°11'0"E 82°11'20"E

19°41'0"N 19°40'40"N 19°40'20"N 19°40'0"N 19°39'40"N 19°39'20"N 19°39'0"N

Adhikariguda — 1.41 Km — Kutiyarigurha — 2.35 Km — Khanda — 0.7 Km — Jamuranda

Estimated Length of 11 kV line = 4.46 Km

Adhikariguda — 1.41 Km — Kutiyarigurha — 2.35 Km — Khanda — 1.96 Km — Batibeda

Estimated Length of 11 kV line = 5.72 Km

Prepared by:

SPARC
Igniting Innovations

Spatial Planning & Analysis Research Centre Pvt. Ltd.
E/11, Infocity, Patia, Bhubaneswar