Plate : SUN 5a

WESCO

Proposed alignment of 33KV line under Infrastructure Development Plan

PH Road - Bondamunda

N

500 250 0 500 Meters

Existing location of 132/33 KV s/s or Tapping location on existing 33 KV line

Proposed location of 33/11 KV s/s

Proposed Power Line

84°51'0"E 84°52'0"E 84°53'0"E 84°54'0"E 84°55'0"E

22°15'0"N 22°14'0"N 22°13'0"N 22°12'0"N

Raulakela Township

Durgapur RF

SOUTH EAST RAILWAY

Bondamunda

2.33 Km

Raulakela

33/11KV PH Road

2.37 Km

Drain

Sunaparbat RF

PH Road — Raurkela — Bondamunda

2.37 Km 2.33 Km

Estimated Length of 33 KV line = 4.7 Km

Prepared by:

SPARC

Spatial Planning & Analysis Research Centre Pvt. Ltd.
E/11, Infocity, Patia, Bhubaneswar